

Fachausschuss Elektrotechnik

der Berufsgenossenschaftlichen Zentrale
für Sicherheit und Gesundheit – BGZ
des Hauptverbandes der gewerblichen Berufsgenossenschaften



BG

Federführung:
Berufsgenossenschaft
der Feinmechanik
und Elektrotechnik

Fachausschuss Elektrotechnik, Postfach 51 05 80, 50941 Köln

INGETEAM, S. A.
C/Pintor Maeztu, 2 1º izda
31008 Pamplona
Spain

Ihre Zeichen/Nachricht vom

Unser Zeichen (Bitte stets angeben)

Bearbeiter

☎ (02 21) 37 78-

Datum

UB.010.17

PI/Ow

6312

27.03.2007

Statement of Compliance

Product: Automatic Disconnection Device

Type: INGECON SUN

Intended Use: The automatic disconnection device is used as a safety interface between the generator and the public low-voltage distribution net. It serves as a replacement for a disconnection switch which is accessible to the distribution net operator at all times.

The device is integral part of the grid-connected PV-converter INGECON SUN 2,5 TL, SUN 3,3 TL, SUN 5 TL.

Standard:
DIN V VDE V 0126-1-1 (2006-02) "Automatic disconnection device between a generator and the public low-voltage grid"

The device fulfils the normative requirements of the above mentioned standard for the intended use.

This document is valid until:

31.12.2011

- Mehlem -
Head of Test- and
Certification Body

VDE 0126-1-1 CERTIFICATE

Manufacturer : INGETEAM S.A.
Avda. Ciudad de la Innovation nº
E-31621 Sarriguren (Navarra). SPAIN
Phone +34 948 288 000 / Fax +34 948 288 001

We hereby declare the conformity of our products Brand/Model :

INGECON® SUN 2.5	INGECON® SUN 3	INGECON® SUN 3.3
INGECON® SUN 3.68	INGECON® SUN 3.8	INGECON® SUN 4.6

Are conforming to the provisions of VDE 0126-1-1 : "Selbsttätige Schaltstelle zwischen einer netzparallele Erzeugungsanlage und dem öffentlichen Niederspannungsnetz" Standard.

Sarriguren, June 2008



Mr. Juan Carlos Jadraque
Head of PV Area Ingeteam S.A.

INGECON® SUN

